

Application for fitness Certificate of School Buildings

(To be filled by the Manager)

1. Name of the School **LOURDES PUBLIC SCHOOL**
2. Location with names of Educational Dist/Sub Dist **Kottayam**
3. Whether fitness Certificate has been issued in previous years and if so the number and date of the last Certificate and the authority who issued it **Issued dated 03.06.2022
Kottayam Municipality**
4. Classification of the building and size (basis for classification)
 - I. Permanent (Single or Multi-storeyed)
 1. Basement Floor - 443.75 sqm
 2. Ground Floor - 1611.93 sqm
 3. First Floor - 1590.49 sqm
 4. Second Floor - 1590.49 sqm
 5. Third Floor - 1590.49 sqm
 - II. Semi-permanent
 - III. Temporary shed
5. Year of construction of different buildings **1997, 2000, 2012, 2017**
6. Short specifications **Permanent Multistoreyed**
7. Foundation and Basement.
 - (i) Rubble in lime mortar/Mud mortar/ Cement mortar or Laterite in lime Mortar/Cement mortar/Mud mortar **Rcc Column Footing and beams
Rubble in Cement Mortar**
 - (ii) Superstructure
Rubble in lime, cement mud or brick, laterite in lime, mud or brick in lime for pillars with Intermediate walls with sun dried bricks **Cement mortar rubble/Brick
in cement**
 - (iii) Doors and windows
Country wood (mention species) **Angali wood**
 - (iv) Wood work wrought and put up country wood (mentions species) full or half bamboo for rafters iron trusses. **Iron Trusses**
 - (v) Kind of roof with short specifications of materials used /RCC/ tiled thatched / A.C. Sheets. **Trapped sheet**
 - (vi) Flooring Cement plastered, Hard broken stone concrete bedding gravel concrete laterite chips or cow dung washed. **Cement plastered and
ceramic tiles**
8. Whether regular attended to or not. Period during Which last maintenance was done. **Yes**

I **Fr. Dr. Philip Nelpunnamparambil**

solemnly declare that the above details furnished are correct to the best of my knowledge.

Place:

Kottayam

Date:

18/05/2023



Manager
MANAGER

LOURDES PUBLIC SCHOOL
COLLECTORATE P.O.
KOTTAYAM-2

To be filled by the Inspecting Officer – Junior Engineer

1. Name of the Officer *Giouthanu R*
2. Period for which Certificate is issued *2023-24*
3. Nature of defect if any
- | | | | |
|---------------------------------|---|------------|---|
| a) Foundation and Basement | } | <i>Nil</i> | <i>Cellar floor = 443.75 m²</i> |
| b) Superstructure | | | <i>Ground floor = 1611.93 m²</i> |
| c) Doors and Windows | | | <i>First floor = 1590.49 m²</i> |
| d) Roof | | | <i>Second floor = 1590.49 m²</i> |
| e) Flooring | | | <i>Third floor = 1590.49 m²</i> |
| f) Miscellaneous (Cracks and C) | | | |
4. Any Major defects noticed which will render the building unsafe in any manner *Nil*
5. Whether maintenance works have been done properly *Yes*
6. Whether the structure is sound or not for conducting classes *Yes, the structure is sound for conducting classes under normal weather conditions.*

Note:

- The stability of the structure should be examined also with the reference to location attitude, intensity of wind Exposure of flood etc.
- Any additional observation it deemed necessary for the certificate may be furnished separately with the certificate

Certified that the school was Inspected by me on *19/6/2023*

And found to be fit/unfit to conduct classes for the period *2023-24 academic year*

For the reason stated above.

Place : *Kottayam*

Date : *19/6/2023*



Giouthanu R

Signature

Designation

തൃതമി ആർ.
 അസിസ്റ്റന്റ് എൻജിനീയർ
 LID & EW, LSGD
 കോട്ടയം മുനിസിപ്പാലിറ്റി
 PEN - 952735